MAINLINE RESILIENT WEDGE GATE VALVES DIN PRODUCTS - DLMV-BB-HDPE SERIES

MAINLINE GATE VALVES FOR DIN HDPE PLASTIC PIPE



DLMV-BB-HDPE (DIN) SERIES (BELL X BELL)		
MODEL #	BELL	BELL
DLMV-99BB-HDPE	90MM	90MM
DLMV-1111BB-HDPE	110MM	110MM
DLMV-1616BB-HDPE	160MM	160MM
DLMV-2020BB-HDPE	200MM	200MM
DLMV-2525BB-HDPE	250MM	250MM
DLMV-3232BB-HDPE	315MM	315MM

250 PSI DUCTILE IRON BODY GATE VALVES

- Bolted Bonnet
- Non-Rising Stem
- Resilient Wedge
- Conforms to AWWA C509 Standards
- Built-in joint restraint grip ring
- 10-Year Warranty



All DLMV-BB-HDPE Series valves include (2 each) stainless steel internal pipe stiffeners. Please note on your purchase order what pipe DR rating is required.



MATERIAL	. CLASS 350 DUCTILE IRON PER ASTM A536, GRADE 65-45-12, AWWA C509
PRESSURE RATING	. 250 PSI
EPOXY COATING	. ANSI/AWWA C116/A21.16-09, NSF 61 & CSA Z245.20-98, 12-14 MIL
RESTRAINT HARDWARE	. 304 STAINLESS STEEL, OPTIONAL 316 STAINLESS STEEL
GASKETS	. HIGH GRADE EPDM RUBBER ANSI/AWWA C111/A21.11, RIB-ENFORCED DESIGN
INSTALLATION	. PER DIN PIPE STANDARDS

SPECIFICATION

All mainline valves shall be resilient wedge and conform to AWWA C153 standards. Material shall be ductile iron per ASTM A536, Grade 65-45-12. Epoxy coating on all interior and exterior surfaces shall be fusion bonded epoxy, 12-14 mil thickness. The epoxy coating shall pass 90-Day immersion tests per CSA Z245.20-98. Two each stainless steel internal pipe stiffeners are included with each valve purchase and are required to be installed into the HDPE pipe before valve installation. Failure to do so will void the Leemco valve warranty. Gate valves shall be push-on bell x bell type with built-in joint restraint grip ring that mechanically connects to the plastic HDPE pipe. All mainline gate valves shall be manufactured by Leemco, Inc., U.S.A.

LEEMCO HAS A LARGE VARIETY OF VALVE ACCESSORIES.

PLEASE VISIT OUR WEBSITE AT LEEMCO.COM



Leemco, Inc. 360 S. Mount Vernon Ave. Colton, CA 92324 Ph: (909) 422-0088 Fx: (909) 422-0086 leemco.com

